







Scale 600 feet to one inch
(Approx.)

WATER FACILITIES:
Old system - Gravity. Water from Fern Lake. Located 5 miles W of Village. Pressure at Park and Center Streets 60 lbs per square inch. 14 Miles of water pipes. 40 Double Hyds System installed in 1875.
New system - Gravity. Water from 2 reservoirs. No. 1 capacity 600,000 gals. Located 3 1/2 miles North of Village. Pressure at Park & Center Streets 140 lbs per square inch. Reservoir No. 2 capacity 80,000 gals. Located 2 1/2 miles E of Village. Pressure at Park and Center Streets 140 lbs per square inch. Reservoirs fed by brooks. 1 Miles of water pipes. 10 Hyds & 3 Hyds System installed in 1900-05. Old and New systems connected at Center & Pearl Streets.

FIRE DEPARTMENT:
Volunteer 20 - Men paid for each service.
1 - Maxim combi hose and pump auto truck with 70 gal booster pump. Capacity of pump 300 gals per minute. 1 - hose cart, 2000' 2 1/2" hose.
Garnewell Fire alarm system one box, alarm by siren whistle.
Public lights electric. Streets asphalt macadam paved. Grades irregular.
No fire limits.
No fire resistive roofing ordinance prohibiting wooden shingle roofs.




MAY 10 1929 C.C.F. 17769

INCLUDING:
FOREST DALE

Division of Maps
MAY 22 1929
Library of Congress


STREETS		SPECIALS	
Barlow Ave.	1-15	Baker, A. T. Wooden Novelty Works & Cider Mill	7
Brandon Road, at Forest Dale	1-24	Baptist Church	6
Carver	1-15	Brandon High School	2
Case	1-15	Inn	2
Center	1-15	National Bank	2
Champlain	1-15	Congregational Church	3
Clay	1-15	Davis, R. C., Inc., Creamery	4
Comant Square	1-15	Episcopal Church	2
Corona	1-15	Fire Department	2
Cross, at Forest Dale	1-15	First National Bank	2
Depot	1-15		
Franklin	1-15		
Goldspink Ave.	1-15		
Grove	1-15		
High, at Forest Dale	1-15		
Main, at Forest Dale	1-15		
Maple	1-15		
Marble	1-15		
Mill, at Forest Dale	1-15		
Otter Creek, see Corona	1-15		
Park	1-15		

* Indicates only one side of Street shown.




Scale 100 Ft to One Inch.
Copy 1929 by the Sandborn Map Co.

Located 1 1/2 miles N.W. of P.O.
No Exposure Any Side









5


5

JAN. 1929
BRANDON
VT.



Scale 100 Ft. to One Inch.
Copyright 1929 by the Surveying Map Co.






FOREST DALE

WATER FACILITIES:
 Located 3 miles N.E. of Brandon Post Office
 Brandon Village Water Works Street Water Mains
 as shown, supplied by Reservoir 110' - Located 1/4 mile
 East of corner of Main & High Sts. No village Hydrants

FIRE DEPT. NONE:
 No Fire Limits - Streets not paved
 Street Lights: Electric
 Grades Level -
 No Fire Resistive Roofing Ordinance - prohibiting
 Wooden shingle roofs -



(3977)

